

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012055.01-R2  
**DATE:** 07/09/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** NewSouth  
**CODE:** 2013-1  
**REVISION DATE:** 09/15/2015

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Doers Window Manufacturing, LLC</b>  <b>4901 Oak Fair Boulevard</b>  <b>Tampa, FL 33610</b>	<p style="text-align: center;"><b>Series "9500-3"</b></p> <p style="text-align: center;"><b>Vinyl Horizontal Roller Window</b></p> <p style="text-align: center;"><b>Replacement or New Construction</b></p> <p style="text-align: center;">Configuration: XOX                      Glazing: IG-1/8" Annealed Glass/Laminate-1/8"                      Annealed Glass/0.105" Solutia Saflex PVB                      Interlayer/1/8" Annealed Glass and IG-1/8" Annealed                      Glass/Laminate-1/8" Annealed Glass/Solutia Saflex                      PVB Interlayer/1/8" Annealed Glass</p> <p>Frame: W-2819mm(111.00")    H-1600mm(63.00")</p> <p>Sash:    W-721mm(28.37")    H-1543mm(60.75")</p> <p>DLO:    W-1295mm(51.00")    H-1543mm(57.25")</p>

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/E1996-05</b> <b>TAS 201/202/203-94</b>	<b>Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2633 Pa (55 psf)</b> <b>Wind Zone 4 - Missile Level D</b> <b>Large Missile Impact Rated</b>

Product Tested By: Architectural Testing Incorporated  
 Report No: D0238.03-401-44/D0238.04-401-44  
 Expiration Date: **June 30, 2018**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
 MANAGEMENT INSTITUTE, INC.**  
**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**Fax: (804) 684-5122**