NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011759.03

DATE: 09/15/2015

CERTIFICATION PROGRAM: Structural

COMPANY: NewSouth

CODE: 2013-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---------------------------------|--|
| Doers Window Manufacturing, LLC | Series "DuraGard" |
| 4901 Oak Fair Boulevard | Vinyl Horizontal Sliding Window |
| Tampa, FL 33610 | w/Aluminum Reinforcement |
| | |
| | Configuration: XX Glazing: Insulating Glass (Annealed) |
| | Frame: W-1829mm(72") H-1651mm(65") |
| | Sash: W-908mm(35.75") H-1568mm(61.75") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------------|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 | Class R-PG30 1829 x 1651 (72 x 65)-HS Design Pressure: 1440 Pa (30 psf) Negative Design Pressure: 1440 Pa (30 psf) |
| | Water Penetration Resistance Test Pressure: 220 Pa(4.60 psf) |

Product Tested By: Architectural Testing Incorporated Report No: A6942.03-501-44 (Specimen 3)

Expiration Date: **December 31, 2015**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Fax: (804) 684-5122