

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012635-R1
DATE: 05/04/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Doers
CODE: 2013-1
REVISION DATE: 09/15/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	Series "Duragard-3" Vinyl Horizontal Sliding Window Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2845mm(112") H-1600mm(63") DLO: W-1327mm(52.25") H-1435mm(56.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG30 2845 x 1600 (112 x 63)-HS Design Pressure: 1436 Pa (30 psf) Negative Design Pressure: 1436 Pa (30 psf) Water Penetration Resistance Test Pressure: 359 Pa(7.5 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02020463
Expiration Date: April 30, 2016

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122