

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012793.06
DATE: 09/17/2015
CERTIFICATION PROGRAM: Structural
COMPANY: NewSouth
CODE: 2013-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610 | Series "Sashlite" Vinyl Horizontal Sliding Window Replacement Configuration: XX Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1518mm(59.75") DLO: W-819mm(32.25") H-1362mm(53.63") |

| SPECIFICATION | PRODUCT RATING |
|------------------------------------|---|
| AAMA/WDMA/101/I.S.2/A440-08 | Class R-PG30 1829 x 1524 (72 x 60)-HS Design Pressure: 1436 Pa (30 psf) Water Penetration Resistance Test Pressure: 287 Pa (6.00 psf) |

Product Tested By: Testing Evaluation Laboratory
Report No: TEL 02031256
Expiration Date: March 31, 2019

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122