

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012633.01-R1
DATE: 05/04/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Doers
CODE: 2013-1
REVISION DATE: 09/15/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	Series "Sashlite-3" Vinyl Horizontal Sliding Window w/Nailing Fin Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2845mm(112") H-1518mm(59.75") DLO: W-1321mm(52") H-1359mm(53.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG20 2845 x 1518 (112 x 60)-HS Design Pressure: 958 Pa (20 psf) Negative Design Pressure: 958 Pa (20 psf) Water Penetration Resistance Test Pressure: 287 Pa(6.0 psf)

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02031264
Expiration Date: March 31, 2019

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122