

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011859.06  
**DATE:** 09/15/2015  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** NewSouth  
**CODE:** 2013-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Doers Window Manufacturing, LLC</b> <b>4901 Oak Fair Boulevard</b> <b>Tampa, FL 33610</b>	<b>Series "9500"</b> <b>Replacement Frame</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XO Glazing: Insulating Glass (Annealed)  Frame: W-1880mm(74.00") H-1575mm(62.00") Sash: W-933mm(36.75") H-1513mm(59.56") DLO: W-851mm(33.50") H-1467mm(57.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG55 1880 x 1575 (74 x 62)-HS</b> <b>Design Pressure: 2633 Pa (55 psf)</b> <b>Negative Design Pressure: 2880 Pa (60 psf)</b> Water Penetration Resistance Test Pressure: 400 Pa(8.35 psf) <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: Architectural Testing Incorporated  
Report No: C7536.07-501-44  
Expiration Date: May 31, 2017

Administrator's Signature:  \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122