NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011841.02-R3

DATE: 02/05/2014

CERTIFICATION PROGRAM: Structural

COMPANY: NewSouth

CODE: 2013-1

REVISION DATE: 09/15/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC	Series "9500"
4901 Oak Fair Boulevard	Horizontal Roller
Tampa, FL 33610	Vinyl Horizontal Sliding Window
	Configuration: XO Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass
	Frame: W-1880mm(74.00") H-1600mm(63.00")
	Vent: W-935mm(36.81") H-1541mm(60.68")
	DLO: W-844mm(33.25") H-1487mm(58.56")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2873 Pa (60 psf) Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated

Report No: D0002.03-401-18 Expiration Date: **January 31, 2018**

Administrator's Signature:

NATIONAL ACCREDITATION AND

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122