

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012633-R1  
DATE: 05/04/2015  
CERTIFICATION PROGRAM: Structural  
COMPANY: Doers  
CODE: 2013-1  
REVISION DATE: 09/15/2015

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Doers Window Manufacturing, LLC</b> <b>4901 Oak Fair Boulevard</b> <b>Tampa, FL 33610</b>	<b>Series "Sashlite-3"</b> <b>Vinyl Horizontal Sliding Window</b>  Configuration: XOX Glazing: Insulating Glass (Annealed)  Frame: W-2845mm(112") H-1518mm(59.75") DLO: W-1321mm(52") H-1359mm(53.5")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG25 2845 x 1518 (112 x 60)-HS</b> <b>Design Pressure: 1197 Pa (25 psf)</b> <b>Negative Design Pressure: 1436 Pa (30 psf)</b> <b>Water Penetration Resistance Test Pressure: 287 Pa(6.0 psf)</b>

Product Tested By: Testing Evaluation Laboratories, Inc.  
Report No: TEL 02031262  
Expiration Date: March 31, 2019

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122