

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011964.06-R2  
**DATE:** 05/09/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** NewSouth  
**CODE:** 2013-1  
**REVISION DATE:** 07/29/2015

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>NewSouth Window Solutions, LLC</b> <b>4901 Oak Fair Boulevard</b> <b>Tampa, FL 33610</b>	<b>Series "4450" Vinyl</b> <b>Impact Single Hung Window</b> <b>New Construction</b>  Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" DuPont PVB Interlayer/1/8" Annealed Glass  Frame: W-940mm(37") H-1575mm(62") Sash: W-879mm(34.62") H-762mm(30") DLO: W-791mm(31.12") H-671mm(26.43")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>ASTM E1886-05/E1996-09</b> <b>AAMA 506-11</b>	<b>Class LC-PG40 940 x 1575 (37 x 62)-H</b> <b>H-LC40 940 x 1575 (37 x 62)</b> <b>Design Pressure: 1915 Pa (40 psf)</b> <b>Negative Design Pressure: 2633 Pa (55 psf)</b> Water Penetration Resistance Test Pressure: 287 Pa (6.00 psf) <b>Wind Zone 4 - Missile Level D</b>

Product Tested By: Element Materials Technology  
Report No: ESP011287P-2/ESP011287P-1 (Gateway)  
Expiration Date: October 31, 2016

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shelby".

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/ Fax: (804) 684-5122