

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011964.12
DATE: 08/05/2015
CERTIFICATION PROGRAM: Structural
COMPANY: NewSouth
CODE: 2013-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
NewSouth Window Solutions, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	Series "4450" Vinyl Impact Single Hung Window Replacement Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" DuPont PVB Interlayer/1/8" Annealed Glass Frame: W-1372mm(54") H-1930mm(76") Sash: W-1310mm(51.56") H-940mm(37") DLO: W-1222mm(48.12") H-851mm(33.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-09	Class LC-PG40 1372 x 1930 (54 x 76)-H H-LC40 1372 x 1930 (54 x 76) Design Pressure: 1915 Pa (40 psf) Water Penetration Resistance Test Pressure: 287 Pa (6.00 psf) Wind Zone 4 - Missile Level D

Product Tested By: Element Materials Technology
Report No: ESP011287P-1
Expiration Date: **October 31, 2016**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Fax: (804) 684-5122