

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012645.03
DATE: 09/14//2015
CERTIFICATION PROGRAM: Structural
COMPANY: NewSouth
CODE: 2013-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	Series "4450" Impact Rated Vinyl Single Hung Window Replacement Configuration: O/X Glazing: IG-1/8" Annealed Glass/ Laminate-1/8" Annealed Glass/0.090" PVB Saflex Interlayer/1/8" Annealed Glass Frame: W-1041mm(41") H-1956mm(77") Sash: W-946mm(37.25") H-933mm(36.75") DLO: W-851mm(33.5") H-845mm(33.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 1915 Pa (40 psf) Negative Design Pressure: 3112 Pa (65 psf) Large Missile Impact Rated

Product Tested By: Element Materials Technology
Report No: ESP013304P-1
Expiration Date: **January 31, 2019**

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122