

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011864.05-R1  
**DATE:** 02/23/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Doers  
**CODE:** 2013-1  
**REVISION DATE:** 07/29/2015

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Doers Window Manufacturing, LLC</b> <b>4901 Oak Fair Boulevard</b> <b>Tampa, FL 33610</b>	<b>"9400"</b> <b>Tilt Replacement Frame</b> <b>Vinyl Single Hung Tilt Window</b>  Configuration: X/O Glazing: Insulating Glass (Annealed)  Frame: W-1372mm(54.00") H-1930mm(76.00") Sash: W-1286mm(50.62") H-960mm(37.81") DLO: W-1264mm(49.75") H-875mm(34.41")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG50 1372 x 1930 (54 x 76)-H</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Negative Design Pressure: 2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 470 Pa(9.82 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Architectural Testing Incorporated  
Report No: C7180.07-501-44  
Expiration Date: **February 28, 2018**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/ Fax: (804) 684-5122