## **NOTICE OF PRODUCT CERTIFICATION**



<b>CERTIFICATION NO:</b>	NI011842-R3
DATE:	02/05/2014
<b>CERTIFICATION PROGRAM:</b>	Structural
COMPANY:	Doers
CODE:	2013-1
<b>REVISION DATE:</b>	07/29/2015

To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS		PRODUCT DES	CRIPTION	
Doers Window Manufacturing, LLC	Series "9450"			
4901 Oak Fair Boulevard	,	Vinyl Single Hung	Tilt Window	
Tampa, FL 33610	New Construction & Replacement			
	Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass			
	Frame:	W-1371mm(54.00")	H-1930mm(76.00")	
	Sash:	W-1282mm(50.50")	H-958mm(37.50")	
	DLO:	W-1263mm(49.75")	H-876mm(34.50")	

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 3112 Pa (65 psf) Large Missile Impact Rated

Product Tested By:ArchitecReport No:C9937.0Expiration Date:January

Architectural Testing Incorporated C9937.03-401-18 January 31, 2018

Shi

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC. 4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122