

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011842-R3
DATE: 02/05/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Doers
CODE: 2013-1
REVISION DATE: 07/29/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610	<p style="text-align: center;">Series "9450"</p> <p style="text-align: center;">Vinyl Single Hung Tilt Window</p> <p style="text-align: center;">New Construction & Replacement</p> <p style="text-align: center;">Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" PVB Interlayer/1/8" Annealed Glass</p> <p>Frame: W-1371mm(54.00") H-1930mm(76.00")</p> <p>Sash: W-1282mm(50.50") H-958mm(37.50")</p> <p>DLO: W-1263mm(49.75") H-876mm(34.50")</p>

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 2633 Pa (55 psf) Negative Design Pressure: 3112 Pa (65 psf) Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated
Report No: C9937.03-401-18
Expiration Date: January 31, 2018

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122