NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI011874.07-R2

DATE: 02/26/2014

CERTIFICATION PROGRAM: Structural

COMPANY: Doers

CODE: 2013-1

REVISION DATE: 07/29/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
Doers Window Manufacturing, LLC	Series "4400"		
4901 Oak Fair Boulevard	Vinyl Single Hung Window		
Tampa, FL 33610	New Construction w/Sill Extender		
		Configuration: Glazing: Insulating Glas	
	Frame:	W-1372mm(54.00")	H-1930mm(76.00")
	Sash:	W-1310mm(51.56")	H-940mm(37.00")
	DLO:	W-1222mm(48.12")	H-851mm(33.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class LC-PG45 1372 x 1930 (54 x 76)-H H-LC45 1372 x 1930 (54 x 76) Design Pressure: 2160 Pa (45 psf) Negative Design Pressure: 2160 Pa (45 psf)
	Water Penetration Resistance Test Pressure: 330 Pa(6.90 psf)

Product Tested By:

Architectural Testing Incorporated

Report No:

C3301.02-501-47

Expiration Date:

October 31, 2016

Administrator's Signature:

Shel

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122