

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012645-R2
DATE: 05/11/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Doers
CODE: 2013-1
REVISION DATE: 07/29/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Doers Window Manufacturing, LLC 4901 Oak Fair Boulevard Tampa, FL 33610</p>	<p>Series "4450" Impact Rated Vinyl Single Hung Window New Construction</p> <p style="text-align: center;">Configuration: O/X Glazing: IG-1/8" Annealed Glass/ Laminate-1/8" Annealed Glass/0.090" PVB Saflex Interlayer/1/8" Annealed Glass</p> <p>Frame: W-1041mm(41") H-1511mm(59.5") Sash: W-981mm(38.63") H-730mm(28.75") DLO: W-962mm(37.88") H-683mm(26.88")</p>

SPECIFICATION	PRODUCT RATING
<p>AAMA/WDMA/CSA 101/L.S.2/A440-08 TAS 201/202/203-94 ASTM E1886-05/ASTM E1996-06</p>	<p>Class R-PG60 1041 x 1524 (41 x 60)-H Design Pressure: 2873 Pa (60 psf) Negative Design Pressure: 3112 Pa (65 psf) Large Missile Impact Rated Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 431 Pa(9.0 psf)</p>

Product Tested By: **Testing Evaluation Laboratories, Inc.**
 Report No: **TEL 02031218/TEL 02031220/TEL 02031222/ESP013304P/ESP013304P-1**
 Expiration Date: **January 31, 2019**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122