

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.20-R3
DATE: 04/04/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Full Lite Fiberglass Out-Swing Side-Hinged Door w/Sidelites & High Dam Sill Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1834mm(72.19") H-2448mm(96.38") Panel: W-908mm(35.75") H-2416mm(95.13") Sidelite: W-405mm(15.94") H-2412mm(94.94") DLO: W-536mm(21.13") H-1603mm(63.13")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14 ASTM E283-04(12)/E547-00(09)(16)	Design Pressure: ±2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Intertek Group, PLC
Report No: H9983.03-301-47/W-1856
Expiration Date: **February 28, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30;/2023