

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.27-R3
DATE: 04/04/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Opaque Fiberglass Out-Swing Side-Hinged Door w/Sidelites & Standard Sill Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-1988mm(78.25") H-2446mm(96.31") Panel: W-1059mm(41.69") H-2412mm(94.94") Sidelite: W-399mm(15.69") H-2412mm(94.94") DLO: W-180mm(7.06") H-1603mm(63.13")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14 ASTM E283-04(12)/E331-00(09)(16)	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf)

Product Tested By: Intertek Group, PLC
Report No: H9984.08-301-47/H9982.12-301-47/W-1856
Expiration Date: March 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023