

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.53-R2
DATE: 11/25/2019
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Glazed Full Lite Fiberglass In-Swing Side-Hinged French Door Assembly Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1880mm(74") H-2080mm(81.88") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG50 1880 x 2080(74 x 82)-LW SHD Design Pressure: ±2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.0 psf)

Product Tested By: National Certified Testing Laboratories
Report No: 310-19-030
Expiration Date: September 30, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S. D." or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023