

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI013981.02-R3  
**DATE:** 02/27/2018  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** JELD-WEN  
**CODE:** 1822-1  
**REVISION DATE:** 07/28/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                    | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                                                                                                                                                |
|---------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>JELD-WEN</b><br><br><b>3737 Lakeport Boulevard</b><br><br><b>Klamath Falls, OR 97601</b> | <b>Series "Architectural" Full Lite</b><br><br><b>Fiberglass In-Swing Side-Hinged Door</b><br><br><b>w/Sidelites</b><br><br>Configuration: OXO<br>Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass<br><br>Frame: W-1985mm(78.13") H-2485mm(97.81")<br><br>Panel: W-1059mm(41.69") H-2412mm(94.94")<br>Sidelite: W-400mm(15.75") H-2409mm(94.81")<br><br>DLO: W-535mm(21.06") H-1601mm(63.06") |

| SPECIFICATION                                                                                                                    | PRODUCT RATING                                                                                                                                                                                                                                                |
|----------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>ASTM E283-04(12)/E330/E330M-14</b><br><b>ASTM E331-00(09)(16)</b><br><b>ASTM E1886-05/13a</b><br><b>ASTM E1996-09/12a/14a</b> | <b>Design Pressure: 2400 Pa (50 psf)</b><br><b>Positive Design Pressure: 2400 Pa (50 psf)</b><br><b>Negative Design Pressure: 2640 Pa (55 psf)</b><br><b>Water Penetration Resistance Test Pressure: 0 Pa (0 psf)</b><br><b>Wind Zone 3 - Missile Level D</b> |

Product Tested By: Intertek Group, PLC  
Report No: H9982.11-301-47  
Expiration Date: **February 28, 2030**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023