

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.07-R4
DATE: 03/01/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/29/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namincertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Opaque Fiberglass Out-Swing Side-Hinged Door w/Sidelites & High Dam Sill Configuration: OXO Glazing: IG-1/8" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass Frame: W-1986mm(78.19") H-2446mm(96.31") Panel: W-1059mm(41.69") H-2414mm(95.06") Sidelite: W-404mm(15.88") H-2412mm(94.94") DLO: W-180mm(7.06") H-1602mm(63.13")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14 ASTM E283-04(12)/E547-00(09)(16) ASTM E1886-05/13a ASTM E1996-09/12a/14a	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek Group, PLC
Report No: H9983.05-301-47-R1
Expiration Date: March 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023