

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.63-R2
DATE: 08/16/2021
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/29/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series “Architectural” Opaque Fiberglass French Out-Swing Side-Hinged Double Door Assembly Configuration: XX Frame: W-2184mm(86") H-2445mm(96.25") Panel: W-1067mm(42") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
ASTM E1886-13a ASTM E1996-17	Design Pressure: ±2400 Pa (50 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek, PLC
Report No: M4812.01-301-47/J7895.01-301-47
Expiration Date: May 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023