

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011604-R3
DATE: 07/09/2013
CERTIFICATION PROGRAM: Structural
COMPANY: LAS Enterprises
CODE: 1124-1
REVISION DATE: 07/13/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
LAS Enterprises 2413 L & A Road Metairie, LA 70001	Series “ 4100 Horizontal Slider WeatherGard III” Vinyl Horizontal Sliding Prime Window Configuration: XX Glazing: IG-Exterior-1/8" Annealed Glass/0.090" DuPont Butacite PVB Interlayer/1/8" Annealed Glass/Interior-1/8" Annealed Glass Frame: W-1879mm(74.00") H-1600mm(63.00") Panel: W-917mm(36.12") H-1530mm(60.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/05/E1996-02/05 TAS 201/202/203-94	Class LC-PG50 1880 x 1600 (74 x 63)-HS HS-LC50 1880 x 1600 (74 x 63) Design Pressure: 2400 Pa (50 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16190-1/NCTL-110-16190-2/NCTL-110-16190-3
Expiration Date: **December 31, 2026**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com