

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011606.01-R4
DATE: 07/09/2013
CERTIFICATION PROGRAM: Structural
COMPANY: LAS Enterprises
CODE: 1124-1
REVISION DATE: 07/13/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
LAS Enterprises 2413 L & A Road Metairie, LA 70001	Series “ 4500 Fixed WeatherGard III” Vinyl Fixed Window Configuration: O Glazing: IG-Exterior-5/32" Annealed Glass/0.090" DuPont Sentry Glass Plus Interlayer/5/32" Annealed Glass/Interior-1/4" Annealed Glass Frame: W-1524mm(60.00") H-2438mm(96.00") DLO: W-1371mm(54.00") H-2286mm(90.00")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/05/E1996-02/05 TAS 201/202/203-94	Class LC-PG50 1524 x 2438 (60 x 96)-FW FW-LC50 1524 x 2438 (60 x 96) Design Pressure: 2400 Pa (50 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16187-1/NCTL-110-16187-2/NCTL-110-16187-3
Expiration Date: **December 31, 2026**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com