NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI011783.02-R1**
DATE:	**01/22/2014**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**MIM Solutions**
CODE:	**2034-1**
REVISION DATE:	**06/07/2017**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
MIM Risk Solutions, Inc. **11220 Metro Parkway, Suite 22** **Ft. Myers, FL 33966**	**"Direct Wall/Interior Ceiling Mount"** **55 mm Aluminum** **Roll-Up Shutter System w/Storm Bars** Configuration: X Frame: W-3676mm(144.75") H-2381mm(93.75") Slat: W-3562mm(140.25")

SPECIFICATION	PRODUCT RATING
TAS 201/203-94 **TAS 202-94 (Structural Only)**	**Design Pressure: 2394 Pa (50 psf)** **Negative Design Pressure: 2394 Pa (50 psf)** **Large Missile Impact Rated**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3917-01(Specimens 7 & 8)
Expiration Date: **September 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122