

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com


Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1079.14	Heritage Door Transom Outswing Profile HWC2W1358 (WMDSS), IPD4 (R&D 25063 Recert of 13190)	101/I.S.2/A440-22	Class R-PG70; Size Tested 2203mm x 1245mm Type-FW; DP +70/-70 psf; Water Test Press 510Pa (10.65psf)	2203mm	1245mm	QCT25-7496.30-R1	8/10/2026	6/22/2026	5/14/2036
413-H-1079.15	Heritage Door Transom Outswing Profile HWC2W1358 (WMDSS), IPD4 (R&D 25063 Recert of 13190)	101/I.S.2/A440-17	Class R-PG70; Size Tested 2203mm x 1245mm Type-FW; DP +70/-70 psf; Water Test Press 510Pa (10.65psf)	2203mm	1245mm	QCT25-7496.30-R1	8/10/2026	6/22/2026	5/14/2036
413-H-1079.16	Heritage Door Transom Outswing Profile HWC2W1358 (WMDSS), IPD4 (R&D 25063 Recert of 13190)	CSA A440 S1-19	Class R-PG70; Size Tested 2203mm x 1245mm Type-FW; DP +3360/-3360 Pa; Water Test Press 510Pa (10.65psf); Can. Air Infil/Exfil. Level=A3	2203mm	1245mm	QCT25-7496.30-R1	8/10/2026	6/22/2026	5/14/2036
413-H-1079.17	Heritage Door Transom Outswing Profile HWC2W1358 (WMDSS), IPD4 (R&D 25063 Recert of 13190)	ASTM E-1996-20 / ASTM E-1886-19	DP +70/-70 psf, Missile D, Wind Zone 4	2203mm	1245mm	QCT25-7496.30-R1	8/10/2026	6/22/2026	5/14/2036

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com