

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1054.22	Heritage Inswing Door Sidelite, Narrow Stiles, IPD4 (R&D 25064 Re-Cert 13065)	101/I.S.2/A440-22	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-65 psf; Water Test Press 470Pa (9.82psf)	1273mm	2507mm	QCT25-7496.26	4/27/2026	5/4/2026	4/17/2036
413-H-1054.23	Heritage Inswing Door Sidelite, Narrow Stiles, IPD4 (R&D 25064 Re-Cert 13065)	101/I.S.2/A440-17	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +65/-65 psf; Water Test Press 470Pa (9.82psf)	1273mm	2507mm	QCT25-7496.26	4/27/2026	5/4/2026	4/17/2036
413-H-1054.24	Heritage Inswing Door Sidelite, Narrow Stiles, IPD4 (R&D 25064 Re-Cert 13065)	CSA A440 S1-19	Class CW-PG65; Size Tested 1273mm x 2507mm Type-FD; DP +3120/-3120 Pa; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=Fixed	1273mm	2507mm	QCT25-7496.26	4/27/2026	5/4/2026	4/17/2036
413-H-1054.25	Heritage Inswing Door Sidelite, Narrow Stiles, IPD4 (R&D 25064 Re-Cert 13065)	ASTM E-1996-20 / ASTM E-1886-19	DP +65/-65 psf, Missile D, Wind Zone 4	1273mm	2507mm	QCT25-7496.26	4/27/2026	5/4/2026	4/17/2036
413-H-1070.180	Ultra 1.75 Gardenaire Door, 8080, LVL Wide Stiles, IPD4 (R&D 23057 & 23058 Recert of 13169 & 13170)	101/I.S.2/A440-22	Class LC-PG50; Size Tested 2438mm x 2500mm Type-SD; DP +50/-55 psf; Water Test Press 360Pa (7.52psf)	2438mm	2500mm	QCT25-7496.18	4/28/2026	5/4/2026	4/20/2036
413-H-1070.181	Ultra 1.75 Gardenaire Door, 8080, LVL Wide Stiles, IPD4 (R&D 23057 & 23058 Recert of 13169 & 13170)	101/I.S.2/A440-17	Class LC-PG50; Size Tested 2438mm x 2500mm Type-SD; DP +50/-55 psf; Water Test Press 360Pa (7.52psf)	2438mm	2500mm	QCT25-7496.18	4/28/2026	5/4/2026	4/20/2036
413-H-1070.182	Ultra 1.75 Gardenaire Door, 8080, LVL Wide Stiles, IPD4 (R&D 23057 & 23058 Recert of 13169 & 13170)	CSA A440 S1-19	Class LC-PG50; Size Tested 2438mm x 2500mm Type-SD; DP +2400/-2640 Pa; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	2438mm	2500mm	QCT25-7496.18	4/28/2026	5/4/2026	4/20/2036
413-H-1070.183	Ultra 1.75 Gardenaire Door, 8080, LVL Wide Stiles, IPD4 (R&D 23057 & 23058 Recert of 13169 & 13170)	ASTM E-1996-20 / ASTM E-1886-19	DP +50/-55 psf, Missile D, Wind Zone 4	2438mm	2500mm	QCT25-7496.18	4/28/2026	5/4/2026	4/20/2036
413-H-1242.10	Heritage Sterling Double Hung - Sapele Core Sash, IPD3 (R&D 25068 Recert 11036 & 11037)	101/I.S.2/A440-22	Class LC-PG60; Size Tested 1054mm x 2424mm Type-H; DP +60/-60 psf; Water Test Press 440Pa (9.19psf)	1054mm	2424mm	QCT26-7783.06	4/28/2026	5/4/2026	4/10/2036
413-H-1242.11	Heritage Sterling Double Hung - Sapele Core Sash, IPD3 (R&D 25068 Recert 11036 & 11037)	101/I.S.2/A440-17	Class LC-PG60; Size Tested 1054mm x 2424mm Type-H; DP +60/-60 psf; Water Test Press 440Pa (9.19psf)	1054mm	2424mm	QCT26-7783.06	4/28/2026	5/4/2026	4/10/2036

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1242.12	Heritage Sterling Double Hung - Sapele Core Sash, IPD3 (R&D 25068 Recert 11036 & 11037)	CSA A440 S1-19	Class LC-PG60; Size Tested 1054mm x 2424mm Type-H; DP +2880/-2880 Pa; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A2	1054mm	2424mm	QCT26-7783.06	4/28/2026	5/4/2026	4/10/2036
413-H-1242.13	Heritage Sterling Double Hung - Sapele Core Sash, IPD3 (R&D 25068 Recert 11036 & 11037)	ASTM E-1996-20 / ASTM E-1886-19	DP +60/-60 psf, Missile D, Wind Zone 3	1054mm	2424mm	QCT26-7783.06	4/28/2026	5/4/2026	4/10/2036
413-H-1244.12	Heritage Casement Crank Out - Maple Core Sash, IPD4 (R&D 25067 Recert 12203/12204)	101/I.S.2/A440-22	Class CW-PG60; Size Tested 914mm x 1829mm Type-C; DP +60/-60 psf; Water Test Press 440Pa (9.19psf)	914mm	1829mm	QCT26-7783.01	4/29/2026	5/4/2026	4/16/2036
413-H-1244.13	Heritage Casement Crank Out - Maple Core Sash, IPD4 (R&D 25067 Recert 12203/12204)	101/I.S.2/A440-17	Class CW-PG60; Size Tested 914mm x 1829mm Type-C; DP +60/-60 psf; Water Test Press 440Pa (9.19psf)	914mm	1829mm	QCT26-7783.01	4/29/2026	5/4/2026	4/16/2036
413-H-1244.14	Heritage Casement Crank Out - Maple Core Sash, IPD4 (R&D 25067 Recert 12203/12204)	CSA A440 S1-19	Class CW-PG60; Size Tested 914mm x 1829mm Type-C; DP +2880/-2880 Pa; Water Test Press 440Pa (9.19psf); Can. Air Infil/Exfil. Level=A3	914mm	1829mm	QCT26-7783.01	4/29/2026	5/4/2026	4/16/2036
413-H-1244.15	Heritage Casement Crank Out - Maple Core Sash, IPD4 (R&D 25067 Recert 12203/12204)	ASTM E-1996-20 / ASTM E-1886-19	DP +60/-60 psf, Missile D, Wind Zone 4	914mm	1829mm	QCT26-7783.01	4/29/2026	5/4/2026	4/16/2036

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com