

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Weather Shield Mfg. Inc.
1 Weathershield Plaza
PO Box 309
Medford, WI 54451-0309

Mfr ID: 449


For more Information visit www.amscert.com


Website: www.weathershield.com

TEL: 715-748-2100

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
449-H-013.58	Premium Casement Impact, (1209), with Premium Casement Picture Impact side mulled (1209) - Single Glazed - (Mull Assembly)	101/I.S.2/A440-11	Class CW-PG65; Size Tested 1016mm Trib Width x 1969mm span (40trib Width/77.5in span) Type-MA; DP +65/-85 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1016mm Trib area	1969mm span	ESP019600P-1705	6/4/2015	6/19/2015	11/6/2029
449-H-013.62	Premium Casement Impact, (1209), with Premium Casement Picture Impact side mulled (1209) - Single Glazed - Mull Assembly	TAS 201/202/203-94	DP +65/-85 psf, Missile D, Wind Zone 4	1975mm	1969mm	ESP019600P-1705	6/4/2015	6/19/2015	11/6/2029
449-H-013.63	Premium Casement Impact, (1209), with Premium Casement Picture Impact side mulled (1209) - Single Glazed - Vertical Mullion	AAMA 450-10	Class CW-PG65; Size Tested 1016mm Trib Width x 1969mm span (40trib Width/77.5in span) Type-MA; DP +65/-85 psf, Wind Zone 4; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1016mm Trib Width	1969mm span	ESP019600P-1705	6/4/2015	6/19/2015	11/6/2029
449-H-013.64	Premium Casement Impact, (1209), with Premium Casement Picture Impact side mulled (1209) - Single Glazed - Vertical Mullion	ASTM E-1996 12/ASTM E-1886-05	DP +65/-85 psf, Wind Zone 4	1975mm	1969mm	ESP019600P-1705	6/4/2015	6/19/2015	11/6/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com