

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
413-H-1287.05	VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set stacked over a VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set, SP (R&D 13119)	101/I.S.2/A440-11	Class LC-PG50; Size Tested 1905mm span/1226mm trib width (75.00 in. span/48.25 in. trib width) Type-MA (Reinforced Combination Horizontal Mull); DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1226mm trib width	1905mm span	ESP015804P-1514	8/18/2017	1/28/2024
413-H-1287.06	VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set stacked over a VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set, SP (R&D 13119)	AAMA 450-10	Class LC-PG50; Size Tested 1905mm span/1226mm trib width (75.00 in span/48.25 in. trib width) Type-MA (Reinforced Combination Horizontal Mull)	1226mm trib width	1905mm span	ESP015804P-1514	8/18/2017	1/28/2024
413-H-1287.07	VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set stacked over a VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set, SP (R&D 13119)	101/I.S.2/A440-11	Class LC-PG50; Size Tested 2445mm span/1378mm trib width (96.25 in span/54.25 in. trib width) Type-MA (Reinforced Combination Vertical Mull); DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	1378mm trib width	2445mm span	ESP015804P-1514	8/18/2017	1/28/2024
413-H-1287.08	VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set stacked over a VistaLuxe Casement combination reinforced mulled to a VistaLuxe Direct Set/Csmt Pic Direct Set, SP (R&D 13119)	AAMA 450-10	Class LC-PG50; Size Tested 2445mm span/1378mm trib width (96.25 in span/54.25 in. trib width) Type-MA (Reinforced Combination Vertical Mull)	1378mm	2445mm	ESP015804P-1514	8/18/2017	1/28/2024

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com