

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011596-R1
DATE: 07/01/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Eurostyle
CODE: 1959-1
REVISION DATE: 02/03/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eurostyle Impact Windows & Doors, LLC 217 Northwest 4th Avenue Hallandale Beach, FL 33009	Series "4500" Glazed Vinyl Out-Swing French Double Doors Configuration: XX Glazing: IG-3/16" Tempered Glass/Laminate-3/16" Annealed Glass/0.090" SentryGlas® Plus by DuPont/3/16" Annealed Glass Frame: W-1880mm(74.00") H-2489mm(98.00") Panel: W-940mm(37.00") H-2413mm(95.00") DLO: W-648mm(25.50") H-2172mm(85.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/05/E1996-02/05 TAS 201/202/203-94	SHD-C65 1880 x 2489 (74 x 98) Design Pressure: 3120 Pa (65 psf) Negative Design Pressure: 3120 Pa (65 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3739-1/NCTL-210-3739-1A
Expiration Date: April 30, 2019

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "S.M.D.", is written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122