

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011238.01-R2  
DATE: 08/21/2012  
CERTIFICATION PROGRAM: Structural  
COMPANY: Energi  
CODE: 1087-1  
REVISION DATE: 01/22/2019

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS                                                                              | PRODUCT DESCRIPTION                                                                                                                                                                                                                              |
|-------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>ENERGI Fenestration Solutions</b><br><b>3035 boul le Corbusier</b><br><b>Laval, Quebec H7L 4C3</b> | <b>"Opera NG Series Patio Door, 4-5/8"</b><br><b>Frame" Vinyl Sliding Glass Door</b><br><br>Configuration: XO<br>Glazing: Insulating Glass (Tempered)<br><br>Frame: W-1811mm(71.29") H-2021mm(79.56")<br>Panel: W-921mm(36.26") H-1950mm(76.77") |

| SPECIFICATION                          | PRODUCT RATING                                                                                                                                                                                                                                                                |
|----------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> | <b>Class R-PG50 1815 x 2018 (71 x 80)</b><br><b>Design Pressure: 2400 Pa (50 psf)</b><br><b>Negative Design Pressure: 2400 Pa (50 psf)</b><br><b>Water Penetration Resistance Test Pressure = 360 Pa (7.5 psf)</b><br><b>Canadian Air Infiltration/Exfiltration Level: A3</b> |

Product Tested By: Air-Ins, Inc.  
Report No: AI-03674-D1  
Expiration Date: August 31, 2023

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122