

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011946-R3
DATE: 05/02/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Energi
CODE: 1087-1
REVISION DATE: 01/22/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ENERGI Fenestration Solutions 3035 boul le Corbusier Laval, Quebec H7L 4C3	Series "Opera NG" Vinyl Sliding Glass Door w/Transom Configuration: O/XO Glazing: Insulating Glass(Tempered) Frame: W-1810mm(71.26") H-2442mm(96.14") Panel: W-920mm(36.22") H-1950mm(76.77") Transom: W-1810mm(71.26") H-402mm(15.82") DLO: W-800mm(31.5") H-1830mm(72")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG40 1810 x 2442 (71 x 96)-SD Design Pressure: 1920 Pa (40 psf) Negative Design Pressure: 1920 Pa (40 psf) Water Penetration Resistance Test Pressure: 360 Pa(7.5 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Air-Ins, Inc.
Report No: AI-03967-A1
Expiration Date: July 31, 2024

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi" or similar, written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122