

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012095
DATE: 08/19/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "3000" Aluminum Flange Frame Fixed Window (Low Design Pressure) Configuration: O Glazing: Monolithic-3/16" Heat Strengthened Glass/0.090" DuPont PVB Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Annealed Glass/Laminate-3/16" Heat Strengthened Glass/0.090" DuPont PVB Interlayer/3/16" Heat Strengthened Glass Frame: W-3048mm(120.00") H-1219mm(48.00") DLO: W-2984mm(117.50") H-1181mm(46.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA 506-11 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Class CW-PG70 3048 x 1219 (120 x 48)-FW Design Pressure: 3351 Pa (70 psf) Negative Design Pressure: 3351 Pa (70 psf) Water Penetration Resistance Test Pressure: 718 Pa(15.00 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA 3010W-2/CTLA 3010W-2A CTLA 3010W-1/CTLA 3010W-1A
Expiration Date: **May 31, 2018**

A handwritten signature in black ink, appearing to be "M.D.", is written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122