

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012125.06  
**DATE:** 09/10/2014  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Continental Glass  
**CODE:** 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Continental Glass Systems, Inc.</b> <b>325 West 74 Place</b> <b>Hialeah, FL 33014</b>	<b>Series "2800 - Lift &amp; Slide"</b> <b>Aluminum Sliding Glass Door</b> <b>w/o Reinforcement</b>  Configuration: OXXO Glazing: Laminate-1/4"Tempered Glass/0.035" Dupont Sentry Glass/1/4" Tempered Glass  Frame: W-5080mm(200.00") H-3048mm(120.00") DLO: W-1111mm(43.75") H-2749mm(108.25")

SPECIFICATION	PRODUCT RATING
<b>TAS 202 (Structural Only)</b> <b>TAS 201/203-94</b>	<b>Design Pressure: 5745 Pa (120 psf)</b> <b>Negative Design Pressure: 5745 Pa (120 psf)</b> <b>Small Missile Impact Rated</b>

Product Tested By: Blackwater Testing, Inc  
Report No: BT-CON-14-002  
Expiration Date: **June 30, 2018**

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
**4794 George Washington Memorial Highway**  
**Hayes, VA 23072**  
**Tel: (804) 684-5124**  
**Fax: (804) 684-5122**