

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012125
DATE: 09/10/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, Inc. 325 West 74 Place Hialeah, FL 33014	Series "2800 - Lift & Slide" Aluminum Sliding Glass Door w/Reinforcement Configuration: OXXO Glazing: Laminate-1/4" Heat Strengthened Glass/0.090" Dupont Sentry Glass/1/4" Heat Strengthened Glass Frame: W-5080mm(200.00") H-3048mm(120.00") DLO: W-1111mm(43.75") H-2749mm(108.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 5745 Pa (120 psf) Negative Design Pressure: 7182 Pa (150 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc
Report No: BT-CON-14-002
Expiration Date: June 30, 2018

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122