

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012134.02
DATE: 11/20/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "5000" Full Glazed Aluminum Outswing Double Side-Hinged Door w/Riser Configuration: XX Glazing: Monolithic Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass or IG-Ext-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass Frame: W-1905mm(75") H-2465mm(97.06") Panel: W-908mm(35.75") H-2388mm(94.03")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ±3591 Pa (75 psf) Class LC-PG75 1905 x 2465 (75 x 97)-SHD Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 539 Pa(11.25 psf)

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3018WA-1R/CTLA 3018WD-1
Expiration Date: **September 30, 2018**

Administrator's Signature: _____ 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122