NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012134.03

DATE: 11/20/2014

CERTIFICATION PROGRAM: Structural

COMPANY: Eastern

CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems	Series "5000" Full Glazed Aluminum
10030 Bavaria Road	Outswing Double Side-Hinged Door
Ft. Myers, FL 33913	Configuration: XX Glazing: Monolithic Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass or IG-Ext-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" SGP Interlayer by DuPont/3/16" Heat Strengthened Glass
	Frame: W-1905mm(75") H-2465mm(97.06")
	Panel: W-908mm(35.75") H-2388mm(94.03")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ±1436 Pa (30 psf) Class LC-PG30 1905 x 2465 (75 x 97)-SHD Negative Design Pressure: 3591 Pa (75 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated Water Penetration Resistance Test Pressure: 215 Pa(4.5 psf)

Product Tested By: Certified Testing Laboratories, Inc.
Report No: CTLA-3018WA-1R/CTLA 3018WD-1R

Expiration Date: September 30, 2018

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Fax: (804) 684-5122