

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012643-R1  
**DATE:** 05/07/2015  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern  
**CODE:** 1783-1  
**REVISION DATE:** 02/11/2016

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b>  <b>16341 Domestic Avenue</b>  <b>Ft. Myers, FL 33912</b>	<p style="text-align: center;"><b>Series "5000" Glazed Aluminum</b></p> <p style="text-align: center;"><b>Out-Swing Side-Hinged French Door</b></p> <p style="text-align: center;"><b>w/Fixed Sidelites, Transom &amp; Sill Riser</b></p> <p style="text-align: center;">Configuration: O/OXO</p> <p style="text-align: center;">Glazing: Monolithic - 3/16" Heat Strengthened Glass/0.090" Kurary Interlayer/3/16" Heat Strengthened Glass or IG - 3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" Kurary Interlayer/3/16" Heat Strengthened Glass</p> <p>Frame:    W-2819mm(111")      H-3073mm(121")</p> <p>Panel:     W-908mm(35.75")      H-2388mm(94.03")</p> <p>Sidelite:  W-914mm(36")        H-2463mm(97")</p> <p>Transom:  W-2819mm(111")      H-609mm(24")</p> <p>DLO:      W-819mm(32.25")      H-2368mm(93.25")</p>

SPECIFICATION	PRODUCT RATING
<b>AAMA 506-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>ASTM E1886-05/E1996-09</b> <b>TAS 201/202/203-94</b>	<b>Design Pressure: ±3830 Pa (80 psf)</b> <b>Class LC-PG80 2819 X 3073 (111 x 121)-SHD</b> <b>Wind Zone 4-Missile Level D</b> <b>Water Penetration Resistance Test Pressure: 574 Pa(12.00 psf)</b> <b>Large Missile Impact Rated</b>

Product Tested By: Certified Testing Laboratories  
 Report No: CTLA 3044WA-1/CTLA 3044WD-1  
 Expiration Date: April 30, 2019

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND**  
**MANAGEMENT INSTITUTE, INC.**  
 4794 George Washington Memorial Highway  
 Hayes, VA 23072  
 Tel: (804) 684-5124  
 Fax: (804) 684-5122