NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012643

DATE: 05/07/2015

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Eastern</u>

CODE: <u>1783-1</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems	Series "5000" Glazed Aluminum
10030 Bavaria Road	Out-Swing Side-Hinged French Door
Ft. Myers, FL 33913	w/Fixed Sidelites, Transom & Sill Riser
	Configuration: O/OXO Glazing: Monolithic - 3/16" Heat Strengthened Glass/0.090" DuPont SGP Interlayer/3/16" Heat Strengthened Glass or IG - 3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" DuPont SGP Interlayer/3/16" Heat Strengthened Glass
	Frame: W-2819mm(111") H-3073mm(121")
	Panel: W-908mm(35.75") H-2388mm(94.03") Sidelite: W-914mm(36") H-2463mm(97") Transom: W-2819mm(111") H-609mm(24")
	DLO: W-819mm(32.25") H-2368mm(93.25")

SPECIFICATION	PRODUCT RATING
AAMA 506-08 AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM E1886-05/E1996-09 TAS 201/202/203-94	Design Pressure: ±3830 Pa (80 psf) Class LC-PG80 2819 X 3073 (111 x 121)-SHD Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 574 Pa(12.00 psf) Large Missile Impact Rated

Product Tested By: Certified Testing Laboratories

Report No: CTLA 3044WA-1/CTLA 3044WD-1

Expiration Date: April 30, 2019

Administrator's Signature: _

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122