NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI012161-R4**
DATE:	**10/16/2014**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Regency**
CODE:	**750-1**
REVISION DATE:	**02/05/2024**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. **2000 Locust Gap Highway** **Mount Carmel, PA 17851**	**Series "6814" Impact Rated** **Vinyl Tilt Double Hung** Configuration: X/X Glazing: IG-Interior-1/8" Tempered Glass/ Exterior-Laminate-1/8" Annealed Glass/0.090" PVB Interlayer by DuPont/1/8" Annealed Glass Frame: W-1016mm(40") H-2134mm(84") Sash: W-945mm(37.19") H-1040mm(40.94)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05** **ASTM E1886-02/04/05/13a** **E1996-02/04/06/09/12a**	**Class R-PG50 1016 x 2134 (40 x 84)-H** **H-R50 1016 x 2134 (40 x 84)** **Design Pressure: 2400 Pa (50 psf)** **Wind Zone 4-Missile Level D** **Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17044-1/NCTL-110-17044-2/W-1901/W-1979
Expiration Date: **September 30, 2030**

Administrator's Signature:_____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com