

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012162-R5
DATE: 10/16/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1
REVISION DATE: 02/05/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "6714" Impact Rated Vinyl Tilt Single Hung Configuration: O/X Glazing: IG-Interior-1/8" Tempered Glass/ Exterior-Laminate-1/8" Annealed Glass/0.090" PVB Interlayer by DuPont/1/8" Annealed Glass Frame: W-1016mm(40") H-2400mm(96") Sash: W-945mm(37.19") H-1192mm(46.94)

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05 ASTM E1886-02/04/05/13a E1996-02/04/06/09/12a	Class R-PG50 1016 x 2439 (40 x 96)-H H-R50 1016 x 2439 (40 x 96) Design Pressure: 2400 Pa (50 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17043-1/NCTL-110-17043-2/W-1901/W-1979
Expiration Date: July 31, 2030

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023