

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 010 - 118.0

Issue Date: 12/15/2014

Revision Date: 1/6/2015

Expiration Date: 12/11/2018

Company Code: 010

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Ventana, USA 6001 Enterprise Drive Export PA 15632	Model: 2050 Impact Garden Window Operator Type: GH Config: Mull, GS-5/16" Ann Lami IG Max Width: 63 Max Height: 63

Referenced Standard:	Product Rating:
AAMA/WDMA/CSA 101/I.S.2/A440-08/11	Class LC-PG50 1600x1600x457 (63x63x22)-Type GH

Qualifying Test Information:	
Test Report No:	ATI-E2513.01-501-44
Test Report Expiration:	12/11/2018

Authorized Signature:

St 2 21

Digitally signed by Steven M. Urich
DN: cn=Steven M. Urich, o=Keystone
Certifications, Inc., ou,
email=surich@keystonecerts.com,
c=US
Date: 2015.01.06 14:45:16 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5
Etters, Pennsylvania 17319
Phone: 717-932-8500
Fax: 717-932-8501