

	Document Title:	Doc No:	FRM B1-43	
	Impact Performance Certification Authorization Report	Rev No: 4	Page: 1	Of: 1
Required By: PRO B1-03				

CAR & Product ID Number: 010 - 201

Issue Date: 12/15/2014

Revision Date: 1/6/2015

Expiration Date: 10/9/2018

Company Code: 010

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Ventana, USA 6001 Enterprise Drive Export PA 15632	Model: 2050 Impact Garden Window Operator Type: GH Config: Mull, GS-5/16" Ann Lami IG Max Width: 63 Max Height: 63 Corresponding Structural CARs: 10-118.0

Referenced Standard:	Product Rating:
ASTM E1886-05/E1996-12	Missile Level D, Wind Zone 3, DP+/-50, 63x63x22

Qualifying Test Information:	
Test Report No:	ATI-D4389.01-501-44
Test Report Expiration:	10/9/2018

Authorized Signature:



Digitally signed by Steven M. Ulrich
DN: cn=Steven M. Ulrich, o=Keystone
Certifications, Inc., ou,
email=surich@keystonecerts.com, c=US
Date: 2015.01.06 14:46:00 -05'00'

Keystone Certifications, Inc.

564 Old York Road, Suite 5

Etters, Pennsylvania 17319

Phone: 717-932-8500

Fax: 717-932-8501