

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010117-R9
DATE: 02/12/2010
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 07/21/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Gladiator/Finishield" In-Swing & Out-Swing Opaque 25 Gauge Steel Side Hinged Door Configuration: X I/S Frame: W-953mm(37.5") H-2076mm(81.75") O/S Frame: W-953mm(37.5") H-2045mm(80.5")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02/E331-00 ASTM E1886-05/E1996-05b AAMA 1304-02	Design Pressure: +50/-50 psf Wind Zone 4-Missile Level D FER-Passed

Product Tested By: Quality Testing, Inc.
Report No: SJW2009-198/W-1897/W-1905/W-2003/W-2025/W-2039
Installation Details: JW152009(1-7)
Expiration Date: December 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023