

# Hallmark® Certificate of Conformance and License (CCL)



Hurd Windows & Doors  
575 S. Whelen Ave.  
Medford, WI 54451

Mfr ID: 436

For more information visit [www.amscert.com](http://www.amscert.com)

Website:

TEL: (715) 748-1716

| Product No.  | Product Name                                | Standard          | Rating                                                                                                                                           | Wide   | High   | Test Report #          | CertDate   | ExpDate    |
|--------------|---------------------------------------------|-------------------|--------------------------------------------------------------------------------------------------------------------------------------------------|--------|--------|------------------------|------------|------------|
| 436-H-660.28 | H3 Casement 36"x78"                         | 101/I.S.2/A440-11 | Class LC-PG50; Size Tested 905mm x 1972mm (36x78in) Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3     | 905mm  | 1972mm | E2293.01-602-44        | 1/29/2015  | 10/31/2024 |
| 436-H-665.06 | Primed Wood Awning 48x48 Mulled             | 101/I.S.2/A440-08 | Class CW-PG50; Size tested 2451x1224mm (97x748in)-AP                                                                                             | 2451mm | 1224mm | ESP011560P-1335        | 11/20/2012 | 10/15/2016 |
| 436-H-665.07 | Primed Wood Awning 48x48 Mulled             | CSA A440 S1-09    | Class CW-PG50; Size Tested 1226mm x 1224mm Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3             | 1226mm | 1224mm | ESP011560P-1335 Rev.CS | 8/6/2014   | 10/12/2016 |
| 436-H-666.10 | Monument Clad Triple Slider Window 119"x59" | 101/I.S.2/A440-11 | Class CW-PG50; Size Tested 3029mm x 1508mm Type-HS; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3             | 3029mm | 1508mm | D6284.01-602-44        | 9/2/2014   | 6/16/2018  |
| 436-H-666.11 | Monument Clad Sliding Window XOX            | 101/I.S.2/A440-08 | Class LC-PG35-Size tested 3029x1507mm (119x59 in) - Type HS                                                                                      | 3029mm | 1507mm | ESP013533P-1434        | 8/20/2013  | 6/12/2017  |
| 436-H-666.12 | Monument Clad Sliding Window XO             | 101/I.S.2/A440-11 | Class CW-PG35; Size Tested 1816mm x 1816mm (72x72in) Type-HS; DP +35/-35 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A2   | 1816mm | 1816mm | D8476.01-602-44        | 2/11/2015  | 9/3/2024   |
| 436-H-666.13 | Monument 3-Wide Clad Horizontal Slider      | 101/I.S.2/A440-11 | Class LC-PG40; Size Tested 3035mm x 1816mm (120x 72in) Type-HS; DP +40/-40 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3 | 3035mm | 1816mm | E2239.01-602-44        | 2/2/2015   | 11/3/2024  |
| 436-H-667.02 | Primed/Wood Direct Set 98x84                | 101/I.S.2/A440-08 | Class CW-PG40; Size tested 2489x2134 mm (98x84 in)-FW                                                                                            | 2489mm | 2134mm | ESP013235P-1421        | 6/14/2013  | 4/19/2017  |
| 436-H-667.03 | Primed/Wood Direct Set 2-Wide 100x84        | 101/I.S.2/A440-08 | Class CW-PG50- Size tested 2540x2134mm (100x84 in)- Type FW; Negative Design Pressure (DP) = 3120Pa (65psf)                                      | 2540mm | 2134mm | ESP013085P-1415        | 7/1/2013   | 4/4/2017   |
| 436-H-667.04 | Primed/Wood Direct Set 2-Wide 100x84        | 101/I.S.2/A440-08 | Class CW-PG50- Size tested 1270x2134mm* (50x84 in*)- Type FW; Negative Design Pressure (DP) = 3120Pa (65psf)                                     | 1270mm | 2134mm | ESP013085P-1415        | 12/6/2013  | 4/4/2017   |