



Structural Performance Certification Authorization Report

Unilux GmbH

Industriegebiet, Nikolaus-Meeth Str. 1
Salmtal, D-54528, Germany

Certification ID:	394-132
Company Code:	394
Certification Date:	2/20/2015
Revision No:	1
Revision Date:	8/14/2024
Expiration Date:	11/15/2027

Product Rating Information:

Model:	HAHS-2 Alum-Clad Wood Lift/Slide Impact Door		
Operator Type:	SD		
Configuration:	Sill/EM/IM, GS-7/16" HS Lami IG		
Referenced Standard:	PA/TAS 201/202/203		
Product Rating:	Large Missile, DP +/-60, 192x96 OX		
Rated Dimensions:	Max Width:	192 in	Max Height: 96 in

Qualifying Test Information:

Test Report No:	NCTL-210-3984-02
Test Report Expiration:	11/15/2027

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2024.08.14
08:45:38 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Structural Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	2/20/2015	Initial Issuance.
1	8/14/2024	Granted 3 Year Extension.