

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Weather Shield Mfg. Inc.
1 Weathershield Plaza
PO Box 309
PO Box 309
Medford, WI 54451-0309

Mfr ID: 449

For more Information visit www.amscert.com

Website:

TEL: 715-748-2100

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
449-H-013.57	Premium Casement Picture Impact, Single Glazed (1209)	101/I.S.2/A440-11	Class CW-PG65; Size Tested 1054mm x 1969mm Type-FW; DP +65/-85 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1054mm	1969mm	ESP019600P-1705	6/19/2015	6/2/2025
449-H-013.60	Premium Casement Picture Impact, Single Glazed (1209)	101/I.S.2/A440-08	Class CW-PG65; Size Tested 1054mm x 1969mm (42" x 78") Type-FW; DP +65/-85 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1054mm	1969mm	ESP019600P-1705	6/19/2015	6/2/2025
449-H-013.90	Premium Casement Picture Impact, Single Glazed (1209)	TAS 201/202/203-94	DP +65/-85 psf, Large Missile Impact	1054mm	1969mm	ESP019600P-1705	11/12/2015	6/2/2025
449-H-013.91	Premium Casement Picture Impact, Single Glazed (1209)	ASTM E-1996 12/ASTM E-1886-05	DP +65/-85 psf, Missile D, Wind Zone 4	1054mm	1969mm	ESP019600P-1705	11/12/2015	6/2/2025

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com