

Hallmark® Certificate of Conformance and License (CCL)





Weather Shield Mfg. Inc.
1 Weathershield Plaza
PO Box 309
PO Box 309
Medford, WI 54451-0309

Mfr ID: 449
For more Information visit www.amscert.com
Website:
TEL: 715-748-2100

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
449-H-017.35	Premium Impact Awning, with Premium Impact Picture Stacked above, Dual Glazed (1210)	101/I.S.2/A440-11	Class LC-PG65; Size Tested 1435mm Trib Width/1054mm Span(56.50" Trib Width/41.50"Span) Type-MA; DP +65/-85 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1435mm Trib Width	1054mm Span	ESP019136P-1688	6/19/2015	4/15/2025
449-H-017.36	Premium Impact Awning, with Premium Impact Picture Stacked above, Dual Glazed (1210)	101/I.S.2/A440-08	Class LC-PG65; Size Tested 1054mm x 2873mm (42" x 113") Type-MA; DP +65/-85 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1054mm	2873mm	ESP019136P-1688	6/19/2015	4/15/2025
449-H-017.37	Premium Impact Awning, with Premium Impact Picture Stacked above, Dual Glazed (1210) - Horizontal Mullion	AAMA 450-10	Class LC-PG65; Size Tested 1435mm Trib Widthx 1054mm span (56.5 trib Width/41.5in span) Type-MA; DP +65/-85 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1435mm Trib Width	1054mm span	ESP019136P-1688	6/19/2015	4/15/2025
449-H-017.38	Premium Impact Awning, with Premium Impact Picture Stacked above, Dual Glazed (1210) - Horizontal Mullion	TAS 201/202/203-94	DP +65/-85 psf, Missile D, Wind Zone 4	1054mm	2873mm	ESP019136P-1688	6/19/2015	4/15/2025
449-H-017.39	Premium Impact Awning, with Premium Impact Picture Stacked above, Dual Glazed (1210) - Horizontal Mullion	ASTM E-1996 12/ASTM E-1886-05	DP +65/-85 psf, Missile D, Wind Zone 4	1054mm	2873mm	ESP019136P-1688	6/22/2015	4/15/2025

WDMA HEREBY CERTIFIES that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected by WDMA, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Rhonda Schotz, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 100 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com