

NOTICE OF PRODUCT CERTIFICATION

S



CERTIFICATION NO: NI016452
DATE: 01/06/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "70" 70NCPW1IMP/ 70RCPW1IMP/70NCATIMP/70RCATIMP Vinyl Fixed Window (Rectangular or Shapes) Configuration: O Glazing: IG-Ext. 1/8" Annealed Glass/Int.-3/32" Annealed Glass/0.090" Solutia Saflex PVB Interlayer/3/32" Annealed Glass Frame: W-1422mm(56") H-1854mm(73") DLO: W-1308mm(51.50") H-1740mm(68.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 ASTM 1886-05 ASTM 1996-12 TAS 201/202/203-94	Class LC-PG50 1422 x 1854 (56 x 73)-FW Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Missile Level D - Wind Zone 4 Large Missile Impact Rated

Product Tested By: Intertek, PLC.
Report No: E1111.03-109-18/E1111.01-109-18/E1111.02-109-18
Expiration Date: December 31, 2028

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023