

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI008050-R4
DATE: 05/21/2007
CERTIFICATION PROGRAM: Structural
COMPANY: Steves and Sons
CODE: 1846-1
REVISION DATE: 07/01/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Steves and Sons Corporation 203 Humble Avenue San Antonio, TX 78225	Round Top Opaque Wood Inswing Double Door w/Surface Bolts Configuration:XX Frame: W-6'3" H-8'0" Panel: W-3'0" H-8'0"

SPECIFICATION	PRODUCT RATING
ASTM E330-02	Design Pressure: +55/-55 psf Qualifying Configurations: X, XX

Product Tested By: Certified Testing Laboratories
Report No: CTLA-1591W-5
Expiration Date: May 31, 2027

A handwritten signature in black ink, appearing to be "Shu".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122